



Installation Instructions:

Feb 2015 v1.1

Description: LED High Bay Luminaire

Model Number: 61025 to 61072 inclusive

**This product must be installed by a competent person.
This product must be earthed.**

Please refer to the individual product label affixed to each Luminaire for specific ratings.

**This Luminaire is designed to be installed in ambient temperatures of -25°C to +35°C
Installation in environments of higher temperatures will invalidate the warranty and may result
in premature failure of the product.**

1. The Luminaire upper lid is designed to match the fixing holes of a conventional Low Bay
2. The Lid can be drilled if necessary to match existing fixing points without affecting the product warranty.
3. The Luminaire must be fitted in such a way that the heat produced from the LED Heat Sink can ventilate naturally through the punched holes in the Luminaire Lid.
4. Under no circumstances must the Luminaire be fitted in such a way that the ventilation holes are blocked or covered.
5. All cable entry through the lid must be suitably protected by cable glands
6. Electrical Connection to the Luminaire must be made to suit the site conditions and must be insulated and earthed.
7. The Luminaire is installed onto the Lid using the 4 x M6 Zinc Plated Steel Set Screws and washers.

Please Note the Inrush Current as per the Driver Specification is:
Typical COLD START 65A(t =445 s measured at 50% I) at 230VAC

Inrush protectors are available from http://www.proconnecting.de/product_info.php?products_id=1046

Please refer to separate datasheet for Dimming/PIR Control

BSS LED Limited
Unit 5
Ashwood Business Park
Ashington
Northumberland NE63 0XD

www.bssled.com

Tel: +44 1670 432400

Company Reg No: 7235861
VAT Reg No: 991 7668 57